

AWIS VALVE REPLACEMENT SEALS

DO YOU HAVE LEAKING VALVE SEALS

Normally it can take up to an hour to remove the old gland bolts, remove the old seals and replace them with new ones.

Now with the DN 80-100 and the DN 150 Valve Replacement Seals you can repair the leaking valve seal in less than half the time it would take to repair the it the old way, thus saving time and money.

AWIS Valve Replacement Seals are made out of EDPM Rubber and comply with requirements of AS 4020—Suitability for Potable Water





TECHNICAL DATA SHEET

**Product Description: EDPM 70 IRHD
Potable Water Grade to AS 4020.**

Typical Properties

W.R.P. Compound Ref.:	9000
Colour:	Black.
Hardness Shore A:	70° ± 5
Tensile Strength MPa:	7
Elongation %:	150
Specific Gravity:	1.63
Operating Temperature range:	up to 100° C.
Typical Applications:	has excellent weathering resistance, good resistance to salt water and to a wide range of chemicals.

The AWIS Valve Replacement seals are available in DN 80-100 and DN 150.
There is a minimum order of 10 No

Disclaimer: While every effort has been made to ensure that the information in this brochure is correct and accurate. Users of AWIS Pty Ltd provided product or information within this document must make their own assessment of suitability for their particular application. Product dimensions are nominal only, and should be verified if critical to a particular installation. No warranty is either expressed, implied, or statutory made by AWIS Pty Ltd Products unless expressly stated in any sale and purchase agreement entered into between AWIS Pty Ltd and the

Distributed by AWIS Pty Ltd



**Australian Water &
Irrigation Solutions** | PTY LTD

A: PO Box 98(1/15 Stud Rd) Bayswater VIC 3153

P: +61 3 9720 2803

F: +61 3 9729 0121

M: David- 0417 052 443 Terry-0412 854 241

E: david@awis.com.au terry@awis.com.au